

NO OBJECTION CERTIFICATE

LICENSE NO. 2) /V/2021

Maduravoyal Fire and Rescue
Service Station.

DATE : 22.10.2021

Subject: Fire and rescue service department – Maduravoyal Fire and Rescue Service Station for purpose of no objection certificate – REG.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date : 14.09.2004
(2) G.O. No.123 School Edu (2) Dept, Date : 14.09.2004
(3) Date of Requisition letter from The Principal,
SV HIGH SCHOOL –16.10.2021

Based on the Govt. order mentioned above and the requisition letter given by the SV HIGH SCHOOL at NO. 113/77 CHETTIAR AGARAM, NOOMBAL, VANAGARAM, CHENNAI-95 Tamil Nadu the building and premises comprises of G+2 owned/occupied by SV HIGH SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and verified on 18.10.2021 in the presence of Principal and that the school is granted NOC for a period of one year from 22.10.2021 to 21.10.2022 subject to the conditions stated below.

THE ABOVE PREMISES INSPECTED BY STATION OFFICER FIRE & RESCUE SERVICES, P. BALACHANDRAN ON 18 / 10 / 2021

CONDITIONS

1. This License is valid for **ONE YEAR** month from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building occupancy capacity should not be more than 4 people per Sq. meter as per the National Building Code-2005.
 - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.

