

TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT
NO OBJECTION CERTIFICATE

Licence No.25/2022
R.C. NO:473/V/mvl/2022

Maduravoyal Fire and Rescue Station.
Date :17.11.2022

Subject: Fire and rescue service department – Maduravoyal
Fire and Rescue Service Station for purpose of
No objection certificate – reg.

Ref : (1) G.O. No.122. School Edu (2) Dept, Date:14.09.2004.
(2) G.O. No.123 School Edu (2) Dept, Date:14.09.2004
(3) THE PRINCIPAL, SV HIGH SCHOOL
Dated: 12.11.2022.

Based on the Govt. order mentioned above and the requisition letter given by the SV HIGH SCHOOL at ,No. 133/77, CHETTIAR AGARAM, NOOMBAL, VANAGARAM, CHENNAI - 600095 Tamil Nadu the building and premises comprises of G+2 owned/occupied by SV HIGH SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and Inspected on 16.11.2022 in the presence of Principal and that the school is granted NOC for a period of one year subject to the conditions stated below.

The Above Premises Inspected By S.Selvan ,Station Officer Maduravoyal, Fire & Rescue Station On 16/11/2022

CONDITIONS

1. This License is valid for one year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building occupancy capacity should not be more than 4 students per Sq. meter as per the National Building Code-2005.
 - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.
 - c) As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms

- shall have to be limited to 45 students.
- d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
 - e) Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Central District at Kilpauk.
 - f) The classrooms should always be in the ground floor upto 3rd standards.
 - g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
 - h) The classroom doors/ windows shall always open outwards.
 - i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
 - j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
 - k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.

If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



(Handwritten Signature) 17/11
நினைவு அலுவலர்
கல்வியும் & கல்யாணமும் துறை
மதுரவாயல் (வாணகரம்)
சென்னை - 600 095.

To:

THE PRINCIPAL,
SV HIGH SCHOOL,
No. 133/77, CHETTIAR AGARAM,
NOOMBAL, VANAGARAM, CHENNAI - 600095.

CC : District Officer, Central Chennai District.

TAMIL NADU FIRE AND RESCUE SERVICE DEPARTMENT
NO OBJECTION CERTIFICATE

Licence No.25/2022
R.C. NO:473/V/mvl/2022

Maduravoyal Fire and Rescue Station.
Date :17.11.2022

Subject: Fire and rescue service department – Maduravoyal
Fire and Rescue Service Station for purpose of
No objection certificate – reg.

Ref : (1) G.O. No.122. School Edu (2) Dept,Date:14.09.2004.
(2) G.O. No.123 School Edu (2) Dept, Date:14.09.2004
(3) THE PRINCIPAL, SV HIGH SCHOOL
Dated: 12.11.2022.


Based on the Govt. order mentioned above and the requisition letter given by the SV HIGH SCHOOL at ,No. 133/77, CHETTIAR AGARAM, NOOMBAL, VANAGARAM, CHENNAI - 600095 Tamil Nadu the building and premises comprises of G+2 owned/occupied by SV HIGH SCHOOL have complied with the fire prevention and fire safety requirements in accordance with rule of State Fire Service Rules, and Inspected on 16.11.2022 in the presence of Principal and that the school is granted NOC for a period of one year subject to the conditions stated below.

The Above Premises Inspected By S.Selvan ,Station Officer Maduravoyal, Fire & Rescue Station On 16/11/2022

CONDITIONS


1. This License is valid for one year from the date of issue.
2. Fire Safety Systems should be maintained in good working condition.
3. Mock drill to be conducted periodically with the help of local fire brigade.
4. Any erection of permanent or temporary structure should be intimated to this department.
5. A trained Fire Service Person, preferably retired one should be appointed.
6. Further to limit the occupant load and to ensure better fire and life safety measures the following additional measures are insisted.
 - a) Building occupancy capacity should not be more than 4 students per Sq. meter as per the National Building Code-2005.
 - b) The staircase treads and flooring shall be treated with rough finish (grooving) to avoid falling of children.

As per Para 6.3 of the BIS Standards IS 14435:1997 as the classrooms have only one entrance, the capacity of the class rooms



- shall have to be limited to 45 students.
- d) Periodical maintenance and care should be taken to maintain all fire protection equipments.
 - e) Mock drill has to be conducted at regular intervals in consultation with the District Officer, Fire and Rescue Services, Chennai City Central District at Kilpauk.
 - f) The classrooms should always be in the ground floor upto 3rd standards.
 - g) The classroom doors/ windows should be made of either non-combustible material or materials with high fire-resistance rating.
 - h) The classroom doors/ windows shall always open outwards.
 - i) The classroom doors/ windows shutters when opened should not obstruct movement along the exit or escape route.
 - j) A Class room shall have two entrances. One door with opening towards the teachers end and the other door on the other end of the class room with only a simple latch / tower bolt arrangement for locking from inside. This door shall not have any arrangement for locking from outside.
 - k) The school shall have proper Evacuation of Plan of action to rescue the children during any emergency in the school premises.


If here is any violation and deviation from the Govt. Rule and Act the License issued will stand cancelled.



The above seal is translated in English as

To:
 THE PRINCIPAL,
 SV HIGH SCHOOL,
 No. 133/77, CHETTIAR AGARAM,
 NOOMBAL, VANAGARAM, CHENNAI - 600095.

*The station officer
 Fire & Rescue Service
 Maduravoyal
 Chennai 600 095*



CC : District Officer, Central Chennai District.

A. THANGAVELU, M.L., M.B.A.,
 ADVOCATE & NOTARY
 GOVERNMENT OF INDIA
 Commissioner of Oaths
 Regn. No: 144/2013
 M.H.A.A. HIGH COURT BUILDING
 CHENNAI-600 104